

FOG 2.0 RER-DERM Summary Block

Hydromechanical FOG Control Device (H-FCD)

Required Information	Tank No. 1	Tank No. 2	Tank No. 3	Tank No. 4
Capacity (gpm)				
FOG Load Capacity (lbs) at 99% Efficiency				
Manufacturer				
Model No.				
3 rd Party Certifier (i.e., PDI, CSA, ASME)				
Interceptor Monitoring Alarm Model No.				
Interceptor Monitoring Device Model No.				
Solid Separator manufacturer and model				
Sampling port manufacturer and model				

Updated: 7/21/2020

The FCD, and associated appurtenances on FOG-approved stamped sheets in this set must be installed on site. Equivalent or similar equipment is not accepted by this Division. Should the FOG-approved plan sheets be voided and/or revised, they shall be submitted to the Building Department, and DERM-Grease accordingly for approval.

ALL EQUIPMENT LABELS MUST VISIBLE AT THE TIME OF THE DERM/BUILDING INSPECTION, AND REMAIN VISIBLE THEREAFTER